

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041

आज़ादी का
अमृत महोत्सव

Water Samples collected “N. K. Bagrodia Public School” Sec – IV, Dwarka, New Delhi - 110078 Vide
Challan No. 213 Dated :- 04.08.2023.

S1:- DJB Supply

S2 :- Drinking Point R. O. water

S.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	11.08.23	11.08.23
2.	Date of Analysis	-----	--	--	12.08.23	12.08.23
3.	Colour	Hazen	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	2.64	1.05
6.	PH value	-----	6.5	8.5	7.58	7.56
7.	Electrical Conductivity	µmho	--	--	254.4	251.8
8.	Total dissolved solids	mg/l	500	2000	165.67	163.67
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil	Nil
10.	Total Alkalinity	mg/l	200	600	82	84
11.	Total Hardness	mg/l	200	600	108	106
12.	Calcium Hardness	mg/l	--	--	75	76
13.	Magnesium Hardness	mg/l	--	--	33	30
14.	Calcium as Ca	mg/l	75	200	30	30.4
15.	Magnesium as Mg	mg/l	30	100	7.92	7.20
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	3.0	2.8
19.	Sulphate	mg/l	200	400	24	24
20.	Chloride	mg/l	250	1000	19	18
21.	Dissolved Iron	mg/l	0.3	N.R.	0.04	0.04
22.	Fluoride	mg/l	1	1.5	0.12	0.12
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.25	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS : As per tested parameters sample - S1 & S2 can be use for drinking purpose.

For N.K. Bagrodia Public School, Dwarka

Chemist


Anjali Kharbanda
Head of School
N.K. Bagrodia Public School, Dwarka

Asst. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41



MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER : NAJAFGARH ZONE
ROOM NO.408, 4TH FLOOR, ZONAL BUILDING, DHANSA STAND,
NAJAFGARH, NEW DELHI 110043



No.DHO/NGZ/2023/1450

Dated 18/7/23

1. Name of the School N.K BAGRODIA PUBLIC SCHOOL
2. School Address SECTOR-4, DWARKA, NEW DELHI-110078
3. No. of Shift ONE Timing 08:00 AM TO 02:00 PM
4. No. of Students: Boys =1661 Girls=1345 Total =3,006
5. No. of Staffs: Male13 Female 78 Total = 91

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient SUFFICIENT
2. The Classrooms are Well Lighted/ ill lighted WELL LIGHTED
3. The Classrooms are Well Ventilated/ ill ventilated WELL VETILATED
4. The Classrooms are kept / Not kept Neat & Clean: NEAT AND CLEAN
5. The Classrooms/Building requires/ do not required Whitewash etc. NOT REQUIRED
6. The Drinking Water is Wholesome/ not wholesome WHOLESOME
7. The Latrine arrangement is Sanitary/ insanitary SANITARY FROM HEALTH POINT OF VIEW.

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate V.GOOD FROM HEALTH POINT OF VIEW AND VALID UP TO ONE YEAR FROM ISSUANCE DATE.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

[Signature]
18/7/23
For N.K. Bagrodia Public School, Dwarka

[Signature]

Deputy Health Officer
Najafgarh Zone

(Remark: Certificate is valid for one year)

[Signature]
Anjali Kharbanda
Head of School

N.K. Bagrodia Public School, Dwarka

[Signature]

Deputy Health Officer
Najafgarh Zone, MCD